






KEYP  
Scale: N.T.S.

- ## FIRE SUPPRESSION NOTES (APPLIES TO ALL SHEETS)

- ## LEGEND

- |        |                             |
|--------|-----------------------------|
| G.C.   | GENERAL CONTRACTOR          |
| P.C.   | PLUMBING CONTRACTOR         |
| F.S.C. | FIRE SUPPRESSION CONTRACTOR |
| H.C.   | HVAC CONTRACTOR             |
| E.C.   | ELECTRICAL CONTRACTOR       |



- |   |  |
|---|--|
|  | — FIRE SUPPRESSION HAZARD CLASSIFICATION |
|   | — ORDINARY HAZARD / GROUP 1              |
|  | "NOTE" SYMBOL (FOR NOTES ON SAME SHEET)  |
|  | ROOM NUMBER                              |
|  | CONNECT TO EXISTING                      |

DRAWING INDEX - FIRE SUPPRESSION	
SHEET	DESCRIPTION
137-F101	PARTIAL FIRST FLOOR PLAN - AREA A
137-F102	PARTIAL FIRST FLOOR PLAN - AREA B


[illegible]

CONSULTANTS:



ARCHITECT/ENGINEERS:

RDC/JOHN POE ARCHITECTS



Drawing Title

PARTIAL FIRST FLOOR PLAN - AREA A

Approved: Project Director

Project Title

Hampton VA, VAMC  
Renovate / Expand SCI, Phase II,  
590-911

Building Number  
137

Location  
Hampton, Va.

Date 2018/08/10

04/26/2013

Project No. 500 011

RDC/JPA Project No. 11004J

Drawing Number

137-F10

Page 72 of 81












[illegible]





## PARTIAL PIPE BASEMENT - AREA A - REMOVALS

Scale: 1/8" = 1'-0"




KEYPLAN

Scale: N.T.S.


[illegible]






Department of






Department of  
Veterans Affairs







Scale: 1/8" = 1'-0"

[illegible]





# WORK

Scale: 1/8" = 1'-0"



Department of  
Veterans Affairs















- GENERAL NOTE**
- A. REFER TO SHEET 137-P001 FOR DRAWING INDEX, LEGEND AND NOTES.
- NOTES:**
- EXISTING TO REMAIN.
  - BOX MOUNTED TRANSFORMER LOCATED ABOVE CEILING TO CONTROL SENSOR OPERATED FAUCET ON FIXTURE(S) BELOW. 120V - 1PH POWER WILL BE LOCATED IN A WIRING BOX ABOVE THE CEILING BY THE E.C. A 0.75" CONDUIT FOR LOW VOLTAGE WIRING STUBBED ABOVE THE CEILING AND EXTENDED DOWN TO AN ELECTRICAL WALL BOX LOCATED BELOW EACH LAVATORY WILL BE PROVIDED BY THE E.C. TRANSFORMER AND LOW VOLTAGE WIRING SHALL BE BY THE P.C. THE P.C. SHALL COORDINATE ALL WORK WITH THE E.C.
  - TRAP PRIMER TO SERVE FD2. REFER TO DETAIL F137-P601.
  - EXTEND NEW 2" DOW. 1.25" DHW & 0.75" DHWR SUPPLY RISERS FROM PIPE BASEMENT BELOW TO ABOVE FIRST FLOOR CEILING TO SERVE RENOVATED AREA AND NEW ADDITION AS INDICATED. PIPING CONTINUED ON SHEET 137-P102.
  - EXISTING 0.75" DOW & DHW PIPING LOCATED IN EXISTING WALL ABOVE FLOOR SLAB SERVING EXISTING MOP SINK IN HAC #1C148 TO REMAIN.
  - EXISTING 2" DOW LOCATED IN EXISTING PLUMBING CHASE ABOVE FLOOR SLAB SERVING EXISTING WATER CLOSETS IN TOILET ROOM #1C103A & TOILET ROOM #1C103B TO REMAIN.
  - EXTEND NEW 0.75" DHWR FROM ABOVE FIRST FLOOR CEILING TO PIPE BASEMENT BELOW. PIPING CONTINUED ON SHEET 137-P102.
  - EXTEND NEW 1.5" DOW. 1" DHW & 0.75" DHWR SUPPLY RISERS FROM PIPE BASEMENT BELOW TO ABOVE FIRST FLOOR CEILING TO SERVE RENOVATED AREA AS INDICATED. PIPING CONTINUED ON SHEET 137-P102.
  - EXTEND 0.75" DOW TO EAST PENTHOUSE ABOVE. PIPING CONTINUED ON SHEET 137-P103.
  - TYPICAL PATIENT LIFT. COORDINATE PIPING WITH PATIENT LIFT AND ASSOCIATED STRUCTURAL MEMBERS.
  - EXISTING MEDICAL GAS RISERS SERVING EXISTING PHASE 1 TO REMAIN.
  - UNDER DEDUCT ALTERNATE 6 & 7 DELETE ALL WORK IN THIS AREA. REFER TO DEDUCT ALTERNATE PLANS ON SHEET 137-P901.
  - UNDER DEDUCT ALTERNATE 4 ALL STORM SYSTEM WORK IN COURTYARD(S) SHALL REMAIN.
  - OUTLINE OF MECHANICAL PENTHOUSE ABOVE. REFER TO SHEET 137-P103.
  - REMOVE AND RETAIN DRINKING FOUNTAIN & RE-INSTALL AFTER TILE IS INSTALLED ON WALL BEHIND FIXTURE. COORDINATE WITH G.C.

**PARTIAL FIRST FLOOR PLAN - AREA B - NEW WORK**

Scale: 1/8" = 1'-0"



**KEYPLAN**

Scale: N.T.S.

CONSULTANTS:

**Heapy Engineering**  
Mechanical Electrical Commissioning Technology  
Nationally Recognized Leader in Sustainability / LEED  
1400 W Dorothy Lane, Dayton OH 45409-1310  
Ph: 937-224-0861 Fax: 937-224-5777 www.heapy.com  
Heapy Project No.: 2011-04008

ARCHITECT/ENGINEERS:

RDC/JOHN POE ARCHITECTS

584 FERNWOOD DRIVE  
ALTIMONTE SPRINGS, FLORIDA  
32701  
937 461 3290 PHONE  
937 461 0260 FAX  
jpo@johnpoe.com

Drawing Title

PARTIAL FIRST FLOOR PLAN - AREA B  
- NEW WORK

Approved: Project Director

Project Title

Hampton VA, VAMC  
Renovate / Expand SCI, Phase II,  
590-911

Building Number  
137

Checked  
RLT

Drawn  
DPB

Location

Hampton, Va.

Date

04/26/2013

Project No.

590-911

RDC/JPA Project No. 11004.004

Drawing Number

137-P104

Dwg. 83 of 135

